



Building Department

336 Town Office Road
Troy, New York 12180
Phone (518) 279-3461
Fax (518) 279-4352
www.townofbrunswick.org

Philip H. Herrington
Town Supervisor


Charles Golden
Code Enforcement Officer

June 12, 2020
M Carley
18 Colehammer Ave
Troy, NY, 12180

Dear Mr Carley,

On June 10th, 2020 a building permit application was submitted for a shed to the above-mentioned parcel. This parcel is in an R-15, which requires 60 feet back from the front, 15 feet from the sides and 20 feet from the rear, the location provided only gives several feet from the side, (depending on which way it is placed out, and would need more detail as to how far back from front).; Therefore, your building permit for the Shed has been denied..

You may appeal this denial and apply for an area variance with the Zoning Board of Appeals. The Zoning Board meets generally on the 3rd Monday of every month; However, In light of current events these dates may change.



Michael McDonald
Code Enforcement Officer
Town Of Brunswick